

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 7)**

Water Level of the accumulated water (at 16:00 on February 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,296 mm (25 mm decrease since 7:00 on February 7)	O.P.+ 2,999 mm (10 mm increase since 7:00 on February 7)	—
	Water level of Turbine Building	O.P.+ 2,712 mm (2 mm increase since 7:00 on February 7)	O.P.+ 3,271 mm (20 mm decrease since 7:00 on February 7)	O.P.+ 2,908 mm (10 mm increase since 7:00 on February 7)	O.P.+ 2,890 mm (5 mm increase since 7:00 on February 7)
	Water level of Reactor Building	O.P.+ 4,271 mm (14 mm increase since 7:00 on February 7)	O.P.+ 3,569 mm (16 mm decrease since 7:00 on February 7)	O.P.+ 3,111 mm (12 mm increase since 7:00 on February 7)	O.P.+ 2,902 mm (4 mm increase since 7:00 on February 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,684 mm (Increase from initial level:5,901 mm, 8 mm increase since 7:00 on February 7) O.P.+ 2,743 mm (Increase from initial level:3,469 mm, 51 mm decrease since 7:00 on February 7) O.P.+ 4,285 mm (Water level from floor:489 mm, No change since 7:00 on February 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:42 on February 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:13 on February 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	-At 17:00 onFebruary 7, we started transffering the accumulated water from the common pool duct to the Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building).				

For quick publication of the data of water level, values are provided as reference values.