

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 8)**

Water Level of the accumulated water (at 7:00 on February 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,258 mm (38 mm decrease since 16:00 on February 7)	O.P.+ 3,010 mm (11 mm increase since 16:00 on February 7)	—
	Water level of Turbine Building	O.P.+ 2,712 mm (No change since 16:00 on February 7)	O.P.+ 3,239 mm (32 mm decrease since 16:00 on February 7)	O.P.+ 2,922 mm (14 mm increase since 16:00 on February 7)	O.P.+ 2,901 mm (11 mm increase since 16:00 on February 7)
	Water level of Reactor Building	O.P.+ 4,286 mm (15 mm increase since 16:00 on February 7)	O.P.+ 3,534 mm (35 mm decrease since 16:00 on February 7)	O.P.+ 3,126 mm (15 mm increase since 16:00 on February 7)	O.P.+ 2,910 mm (8 mm increase since 16:00 on February 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,684 mm (Increase from initial level:5,901 mm, No change since 16:00 on February 7) O.P.+ 2,732 mm (Increase from initial level:3,458 mm, 11 mm decrease since 16:00 on February 7) O.P.+ 4,286 mm (Water level from floor:490 mm, 1 mm increase since 16:00 on February 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:42 on February 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:13 on February 6   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	From 5:00 PM on February 7 to 8:18 AM on February 8, we conducted transferring the accumulated water in the Common Pool duct to the Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building).				

For quick publication of the data of water level, values are provided as reference values.