

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 8)**

Water Level of the accumulated water (at 16:00 on February 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,237 mm (21 mm decrease since 7:00 on February 8)	O.P.+ 3,017 mm (7 mm increase since 7:00 on February 8)	—
	Water level of Turbine Building	O.P.+ 2,713 mm (1 mm increase since 7:00 on February 8)	O.P.+ 3,218 mm (21 mm decrease since 7:00 on February 8)	O.P.+ 2,929 mm (7 mm increase since 7:00 on February 8)	O.P.+ 2,907 mm (6 mm increase since 7:00 on February 8)
	Water level of Reactor Building	O.P.+ 4,286 mm (No change since 7:00 on February 8)	O.P.+ 3,512 mm (22 mm decrease since 7:00 on February 8)	O.P.+ 3,134 mm (8 mm increase since 7:00 on February 8)	O.P.+ 2,917 mm (7 mm increase since 7:00 on February 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,685 mm (Increase from initial level:5,902 mm, 1 mm increase since 7:00 on February 8) O.P.+ 2,706 mm (Increase from initial level:3,432 mm, 26 mm decrease since 7:00 on February 8) O.P.+ 4,286 mm (Water level from floor:490 mm, No change since 7:00 on February 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:42 on February 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:13 on February 6   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.