

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 12)**

Water Level of the accumulated water (at 16:00 on February 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,045 mm (16 mm increase since 7:00 on February 12)	O.P.+ 3,065 mm (7 mm decrease since 7:00 on February 12)	—
	Water level of Turbine Building	O.P.+ 2,715 mm (No change since 7:00 on February 12)	O.P.+ 3,052 mm (12 mm increase since 7:00 on February 12)	O.P.+ 2,970 mm (16 mm decrease since 7:00 on February 12)	O.P.+ 2,968 mm (3 mm increase since 7:00 on February 12)
	Water level of Reactor Building	O.P.+ 4,112 mm (15 mm decrease since 7:00 on February 12)	O.P.+ 3,329 mm (3 mm decrease since 7:00 on February 12)	O.P.+ 3,189 mm (10 mm decrease since 7:00 on February 12)	O.P.+ 2,974 mm (4 mm increase since 7:00 on February 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,673 mm (Increase from initial level:5,890 mm, 19 mm decrease since 7:00 on February 12) O.P.+ 2,562 mm (Increase from initial level:3,288 mm, 94 mm increase since 7:00 on February 12) O.P.+ 4,286 mm (Water level from floor:490 mm, No change since 7:00 on February 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 13:42 on February 6 to 10:15 on February 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:02 on February 12)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:44 on February 12 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:34 on February 12 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*1 From January 24 11:03 to February 12 10:25, we transferred the accumulated water from the basement of Unit 3 Turbine Building to the Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) *2 We stopped operation of the Second Cesium Absorption Apparatus (SARRY) at 8:34 on February 12 due to the accumulated water transferring pump installation at Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building). Therefore, we started operation of the Cesium Absorption Apparatus at 10:31 the same day, and it reached steady flow at 10:44.				

For quick publication of the data of water level, values are provided as reference values.