

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 13)**

Water Level of the accumulated water (at 7:00 on February 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,095 mm (50 mm increase since 16:00 on February 12)	O.P.+ 3,052 mm (13 mm decrease since 16:00 on February 12)	—
	Water level of Turbine Building	O.P.+ 2,716 mm (1 mm increase since 16:00 on February 12)	O.P.+ 3,096 mm (44 mm increase since 16:00 on February 12)	O.P.+ 2,941 mm (29 mm decrease since 16:00 on February 12)	O.P.+ 2,957 mm (11 mm decrease since 16:00 on February 12)
	Water level of Reactor Building	O.P.+ 4,108 mm (4 mm decrease since 16:00 on February 12)	O.P.+ 3,374 mm (45 mm increase since 16:00 on February 12)	O.P.+ 3,152 mm (37 mm decrease since 16:00 on February 12)	O.P.+ 2,965 mm (9 mm decrease since 16:00 on February 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,636 mm (Increase from initial level:5,853 mm, 37 mm decrease since 16:00 on February 12) O.P.+ 2,623 mm (Increase from initial level:3,349 mm, 61 mm increase since 16:00 on February 12) O.P.+ 4,287 mm (Water level from floor:491 mm, 1 mm increase since 16:00 on February 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:02 on February 12)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:44 on February 12 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:34 on February 12 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.