

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 13)**

Water Level of the accumulated water (at 16:00 on February 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,125 mm (30 mm increase since 7:00 on February 13)	O.P.+ 3,042 mm (10 mm decrease since 7:00 on February 13)	—
	Water level of Turbine Building	O.P.+ 2,715 mm (1 mm decrease since 7:00 on February 13)	O.P.+ 3,120 mm (24 mm increase since 7:00 on February 13)	O.P.+ 2,923 mm (18 mm decrease since 7:00 on February 13)	O.P.+ 2,949 mm (8 mm decrease since 7:00 on February 13)
	Water level of Reactor Building	O.P.+ 4,114 mm (6 mm increase since 7:00 on February 13)	O.P.+ 3,397 mm (23 mm increase since 7:00 on February 13)	O.P.+ 3,134 mm (18 mm decrease since 7:00 on February 13)	O.P.+ 2,959 mm (6 mm decrease since 7:00 on February 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,610 mm (Increase from initial level:5,827 mm, 26 mm decrease since 7:00 on February 13) O.P.+ 2,662 mm (Increase from initial level:3,388 mm, 39 mm increase since 7:00 on February 13) O.P.+ 4,288 mm (Water level from floor:492 mm, 1 mm increase since 7:00 on February 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:02 on February 12)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:44 on February 12 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:34 on February 12 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.