

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 14)**

Water Level of the accumulated water (at 7:00 on February 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,164 mm (39 mm increase since 16:00 on February 13)	O.P.+ 3,025 mm (17 mm decrease since 16:00 on February 13)	—
	Water level of Turbine Building	O.P.+ 2,717 mm (2 mm increase since 16:00 on February 13)	O.P.+ 3,155 mm (35 mm increase since 16:00 on February 13)	O.P.+ 2,902 mm (21 mm decrease since 16:00 on February 13)	O.P.+ 2,933 mm (16 mm decrease since 16:00 on February 13)
	Water level of Reactor Building	O.P.+ 4,127 mm (13 mm increase since 16:00 on February 13)	O.P.+ 3,427 mm (30 mm increase since 16:00 on February 13)	O.P.+ 3,109 mm (25 mm decrease since 16:00 on February 13)	O.P.+ 2,945 mm (14 mm decrease since 16:00 on February 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,561 mm (Increase from initial level:5,778 mm, 49 mm decrease since 16:00 on February 13) O.P.+ 2,722 mm (Increase from initial level:3,448 mm, 60 mm increase since 16:00 on February 13) O.P.+ 4,287 mm (Water level from floor:491 mm, 1 mm decrease since 16:00 on February 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:02 on February 12)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:44 on February 12 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:34 on February 12 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.