

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 14)**

Water Level of the accumulated water (at 16:00 on February 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,186 mm (22 mm increase since 7:00 on February 14)	O.P.+ 3,016 mm (9 mm decrease since 7:00 on February 14)	—
	Water level of Turbine Building	O.P.+ 2,716 mm (1 mm decrease since 7:00 on February 14)	O.P.+ 3,174 mm (19 mm increase since 7:00 on February 14)	O.P.+ 2,898 mm (4 mm decrease since 7:00 on February 14)	O.P.+ 2,921 mm (12 mm decrease since 7:00 on February 14)
	Water level of Reactor Building	O.P.+ 4,136 mm (9 mm increase since 7:00 on February 14)	O.P.+ 3,450 mm (23 mm increase since 7:00 on February 14)	O.P.+ 3,103 mm (6 mm decrease since 7:00 on February 14)	O.P.+ 2,935 mm (10 mm decrease since 7:00 on February 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,497 mm (Increase from initial level:5,714 mm, 64 mm decrease since 7:00 on February 14) O.P.+ 2,758 mm (Increase from initial level:3,484 mm, 36 mm increase since 7:00 on February 14) O.P.+ 4,287 mm (Water level from floor:491 mm, No change since 7:00 on February 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 11:02 on February 12 to 13:38 on February 14)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:44 on February 12 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:34 on February 12 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.