

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 15)**

Water Level of the accumulated water (at 7:00 on February 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,223 mm (37 mm increase since 16:00 on February 14)	O.P.+ 3,022 mm (6 mm increase since 16:00 on February 14)	—
	Water level of Turbine Building	O.P.+ 2,716 mm (No change since 16:00 on February 14)	O.P.+ 3,206 mm (32 mm increase since 16:00 on February 14)	O.P.+ 2,931 mm (33 mm increase since 16:00 on February 14)	O.P.+ 2,917 mm (4 mm decrease since 16:00 on February 14)
	Water level of Reactor Building	O.P.+ 4,157 mm (21 mm increase since 16:00 on February 14)	O.P.+ 3,482 mm (32 mm increase since 16:00 on February 14)	O.P.+ 3,139 mm (36 mm increase since 16:00 on February 14)	O.P.+ 2,929 mm (6 mm decrease since 16:00 on February 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,210 mm (Increase from initial level:5,427 mm, 287 mm decrease since 16:00 on February 14) O.P.+ 2,820 mm (Increase from initial level:3,546 mm, 62 mm increase since 16:00 on February 14) O.P.+ 4,288 mm (Water level from floor:492 mm, 1 mm increase since 16:00 on February 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:44 on February 12 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:34 on February 12 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.