

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 18)**

Water Level of the accumulated water (at 7:00 on February 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,390 mm (34 mm increase since 16:00 on February 17)	O.P.+ 2,958 mm (17 mm decrease since 16:00 on February 17)	—
	Water level of Turbine Building	O.P.+ 2,719 mm (No change since 16:00 on February 17)	O.P.+ 3,351 mm (29 mm increase since 16:00 on February 17)	O.P.+ 2,825 mm (19 mm decrease since 16:00 on February 17)	O.P.+ 2,865 mm (16 mm decrease since 16:00 on February 17)
	Water level of Reactor Building	O.P.+ 4,243 mm (18 mm increase since 16:00 on February 17)	O.P.+ 3,623 mm (31 mm increase since 16:00 on February 17)	O.P.+ 3,032 mm (21 mm decrease since 16:00 on February 17)	O.P.+ 2,880 mm (17 mm decrease since 16:00 on February 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,158 mm (Increase from initial level:5,375 mm, 2 mm increase since 16:00 on February 17) O.P.+ 2,797 mm (Increase from initial level:3,523 mm, 11 mm decrease since 16:00 on February 17) O.P.+ 4,289 mm (Water level from floor:493 mm, 2 mm increase since 16:00 on February 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:55 on February 15)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:55 on February 15   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.