

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 18)**

Water Level of the accumulated water (at 16:00 on February 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,399 mm (9 mm increase since 7:00 on February 18)	O.P.+ 2,949 mm (9 mm decrease since 7:00 on February 18)	—
	Water level of Turbine Building	O.P.+ 2,719 mm (No change since 7:00 on February 18)	O.P.+ 3,358 mm (7 mm increase since 7:00 on February 18)	O.P.+ 2,822 mm (3 mm decrease since 7:00 on February 18)	O.P.+ 2,853 mm (12 mm decrease since 7:00 on February 18)
	Water level of Reactor Building	O.P.+ 4,257 mm (14 mm increase since 7:00 on February 18)	O.P.+ 3,640 mm (17 mm increase since 7:00 on February 18)	O.P.+ 3,024 mm (8 mm decrease since 7:00 on February 18)	O.P.+ 2,874 mm (6 mm decrease since 7:00 on February 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,160 mm (Increase from initial level:5,377 mm, 2 mm increase since 7:00 on February 18) O.P.+ 2,794 mm (Increase from initial level:3,520 mm, 3 mm decrease since 7:00 on February 18) O.P.+ 4,288 mm (Water level from floor:492 mm, 1 mm decrease since 7:00 on February 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 14:12 on February 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:55 on February 15)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:55 on February 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.