

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 19)**

Water Level of the accumulated water (at 7:00 on February 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,349 mm (50 mm decrease since 16:00 on February 18)	O.P.+ 2,955 mm (6 mm increase since 16:00 on February 18)	—
	Water level of Turbine Building	O.P.+ 2,719 mm (No change since 16:00 on February 18)	O.P.+ 3,315 mm (43 mm decrease since 16:00 on February 18)	O.P.+ 2,860 mm (38 mm increase since 16:00 on February 18)	O.P.+ 2,850 mm (3 mm decrease since 16:00 on February 18)
	Water level of Reactor Building	O.P.+ 4,271 mm (14 mm increase since 16:00 on February 18)	O.P.+ 3,609 mm (31 mm decrease since 16:00 on February 18)	O.P.+ 3,063 mm (39 mm increase since 16:00 on February 18)	O.P.+ 2,864 mm (10 mm decrease since 16:00 on February 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,163 mm (Increase from initial level:5,380 mm, 3 mm increase since 16:00 on February 18) O.P.+ 2,786 mm (Increase from initial level:3,512 mm, 8 mm decrease since 16:00 on February 18) O.P.+ 4,288 mm (Water level from floor:492 mm, No change since 16:00 on February 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 14:12 on February 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:55 on February 15)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:55 on February 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.