Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 20)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on February 20)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,257 mm (23 mm decrease since 7:00 on February 20)	O.P.+ 2,985 mm (7 mm increase since 7:00 on February 20)	-
	Water level of Turbine Building	O.P.+ 2,719 mm (1 mm decrease since 7:00 on February 20)	O.P.+ 3,234 mm (22 mm decrease since 7:00 on February 20)	O.P.+ 2,890 mm (6 mm increase since 7:00 on February 20)	O.P.+ 2,870 mm (7 mm increase since 7:00 on February 20)
	Water level of Reactor Building	O.P.+ 4,269 mm (No change since 7:00 on February 20)	O.P.+ 3,529 mm (21 mm decrease since 7:00 on February 20)	O.P.+ 3,096 mm (6 mm increase since 7:00 on February 20)	O.P.+ 2,881 mm (5 mm increase since 7:00 on February 20)
	Water level of each building in the Centralized Radiation Waste	Process Main Building	O.P.+ 4,172 mm (Increase from initial level:5,389 mm, 2 mm increase since 7:00 on February 20)		
		High Temperature Incinerator Building	O.P.+ 2,767 mm (Increase from initial level:3,493 mm, 3 mm decrease since 7:00 on February 20)		
	Treatment Facility	On-site Bunker Building	O.P.+ 4,289 mm (Water level from floor:493 mm, No change since 7:00 on February 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 14:12 on February 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:55 on February 15)	_
		Unit 5 and 6			
		_			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:55 on February 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	The data for the water level of the Unit 1 Reactor Building is the data as of February 20 7:00, since it was unmeasureable by remote control.				

% For quick publication of the data of water level, values are provided as reference values.