

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 21)**

Water Level of the accumulated water (at 16:00 on February 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,193 mm (23 mm decrease since 7:00 on February 21)	O.P.+ 3,001 mm (6 mm increase since 7:00 on February 21)	—
	Water level of Turbine Building	O.P.+ 2,719 mm (1 mm decrease since 7:00 on February 21)	O.P.+ 3,180 mm (21 mm decrease since 7:00 on February 21)	O.P.+ 2,908 mm (6 mm increase since 7:00 on February 21)	O.P.+ 2,887 mm (6 mm increase since 7:00 on February 21)
	Water level of Reactor Building	O.P.+ 4,238 mm (31 mm decrease since 7:00 on February 20)	O.P.+ 3,478 mm (17 mm decrease since 7:00 on February 21)	O.P.+ 3,115 mm (6 mm increase since 7:00 on February 21)	O.P.+ 2,897 mm (5 mm increase since 7:00 on February 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,185 mm (Increase from initial level:5,402 mm, 11 mm increase since 7:00 on February 21) O.P.+ 2,956 mm (Increase from initial level:3,682 mm, 192 mm increase since 7:00 on February 21) O.P.+ 4,290 mm (Water level from floor:494 mm, 1 mm increase since 7:00 on February 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 14:12 on February 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:55 on February 15)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:25 on February 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*1 It is compared with the data of 7:00 February 20 due to the lack of the data after 16:00 February 20 since the water level of the Unit 1 Reactor Building had not been seen remotely. *2 At 8:34, February 21, we stopped the second cesium absorption apparatus (SARRY) due to a filter cleaning. We finished the cleaning and started the apparatus at 13:19 on the same day, and confirmed that the flow reached normal level at 14:25.				

For quick publication of the data of water level, values are provided as reference values.