

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 22)**

Water Level of the accumulated water (at 7:00 on February 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,156 mm (37 mm decrease since 16:00 on February 21)	O.P.+ 2,999 mm (2 mm decrease since 16:00 on February 21)	—
	Water level of Turbine Building	O.P.+ 2,720 mm (1 mm increase since 16:00 on February 21)	O.P.+ 3,148 mm (32 mm decrease since 16:00 on February 21)	O.P.+ 2,903 mm (5 mm decrease since 16:00 on February 21)	O.P.+ 2,893 mm (6 mm increase since 16:00 on February 21)
	Water level of Reactor Building	O.P.+ 4,216 mm (22 mm decrease since 16:00 on February 21)	O.P.+ 3,446 mm (32 mm decrease since 16:00 on February 21)	O.P.+ 3,112 mm (3 mm decrease since 16:00 on February 21)	O.P.+ 2,904 mm (7 mm increase since 16:00 on February 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,188 mm (Increase from initial level:5,405 mm, 3 mm increase since 16:00 on February 21) O.P.+ 3,004 mm (Increase from initial level:3,730 mm, 48 mm increase since 16:00 on February 21) O.P.+ 4,291 mm (Water level from floor:495 mm, 1 mm increase since 16:00 on February 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 14:12 on February 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:55 on February 15)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:25 on February 21   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.