

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 22)**

Water Level of the accumulated water (at 16:00 on February 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,134 mm (22 mm decrease since 7:00 on February 22)	O.P.+ 3,000 mm (1 mm increase since 7:00 on February 22)	—
	Water level of Turbine Building	O.P.+ 2,720 mm (No change since 7:00 on February 22)	O.P.+ 3,127 mm (21 mm decrease since 7:00 on February 22)	O.P.+ 2,904 mm (1 mm increase since 7:00 on February 22)	O.P.+ 2,895 mm (2 mm increase since 7:00 on February 22)
	Water level of Reactor Building	O.P.+ 4,205 mm (11 mm decrease since 7:00 on February 22)	O.P.+ 3,425 mm (21 mm decrease since 7:00 on February 22)	O.P.+ 3,111 mm (1 mm decrease since 7:00 on February 22)	O.P.+ 2,904 mm (No change since 7:00 on February 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,191 mm (Increase from initial level:5,408 mm, 3 mm increase since 7:00 on February 22) O.P.+ 3,034 mm (Increase from initial level:3,760 mm, 30 mm increase since 7:00 on February 22) O.P.+ 4,290 mm (Water level from floor:494 mm, 1 mm decrease since 7:00 on February 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 14:12 on February 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:55 on February 15)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:25 on February 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.