

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 25)**

Water Level of the accumulated water (at 16:00 on February 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,114 mm (29 mm increase since 7:00 on February 25)	O.P.+ 2,981 mm (9 mm decrease since 7:00 on February 25)	—
	Water level of Turbine Building	O.P.+ 2,724 mm (3 mm increase since 7:00 on February 25)	O.P.+ 3,109 mm (22 mm increase since 7:00 on February 25)	O.P.+ 2,855 mm (16 mm decrease since 7:00 on February 25)	O.P.+ 2,882 mm (9 mm decrease since 7:00 on February 25)
	Water level of Reactor Building	O.P.+ 4,115 mm (2 mm decrease since 7:00 on February 25)	O.P.+ 3,386 mm (21 mm increase since 7:00 on February 25)	O.P.+ 3,063 mm (18 mm decrease since 7:00 on February 25)	O.P.+ 2,897 mm (8 mm decrease since 7:00 on February 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,202 mm (Increase from initial level:5,419 mm, 1 mm increase since 7:00 on February 25) O.P.+ 3,045 mm (Increase from initial level:3,771 mm, 50 mm decrease since 7:00 on February 25) O.P.+ 4,291 mm (Water level from floor:495 mm, 1 mm increase since 7:00 on February 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:29 on February 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:25 on February 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.