

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 26)**

Water Level of the accumulated water (at 7:00 on February 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,153 mm (39 mm increase since 16:00 on February 25)	O.P.+ 2,964 mm (17 mm decrease since 16:00 on February 25)	—
	Water level of Turbine Building	O.P.+ 2,724 mm (No change since 16:00 on February 25)	O.P.+ 3,145 mm (36 mm increase since 16:00 on February 25)	O.P.+ 2,833 mm (22 mm decrease since 16:00 on February 25)	O.P.+ 2,868 mm (14 mm decrease since 16:00 on February 25)
	Water level of Reactor Building	O.P.+ 4,106 mm (9 mm decrease since 16:00 on February 25)	O.P.+ 3,421 mm (35 mm increase since 16:00 on February 25)	O.P.+ 3,044 mm (19 mm decrease since 16:00 on February 25)	O.P.+ 2,882 mm (15 mm decrease since 16:00 on February 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,205 mm (Increase from initial level:5,422 mm, 3 mm increase since 16:00 on February 25) O.P.+ 2,964 mm (Increase from initial level:3,690 mm, 81 mm decrease since 16:00 on February 25) O.P.+ 4,291 mm (Water level from floor:495 mm, No change since 16:00 on February 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:29 on February 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:25 on February 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.