

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 26)**

Water Level of the accumulated water (at 16:00 on February 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,176 mm (23 mm increase since 7:00 on February 26)	O.P.+ 2,954 mm (10 mm decrease since 7:00 on February 26)	—
	Water level of Turbine Building	O.P.+ 2,724 mm (No change since 7:00 on February 26)	O.P.+ 3,164 mm (19 mm increase since 7:00 on February 26)	O.P.+ 2,820 mm (13 mm decrease since 7:00 on February 26)	O.P.+ 2,858 mm (10 mm decrease since 7:00 on February 26)
	Water level of Reactor Building	O.P.+ 4,109 mm (3 mm increase since 7:00 on February 26)	O.P.+ 3,442 mm (21 mm increase since 7:00 on February 26)	O.P.+ 3,030 mm (14 mm decrease since 7:00 on February 26)	O.P.+ 2,873 mm (9 mm decrease since 7:00 on February 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,206 mm (Increase from initial level:5,423 mm, 1 mm increase since 7:00 on February 26) O.P.+ 2,921 mm (Increase from initial level:3,647 mm, 43 mm decrease since 7:00 on February 26) O.P.+ 4,291 mm (Water level from floor:495 mm, No change since 7:00 on February 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:29 on February 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:25 on February 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.