

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 27)**

Water Level of the accumulated water (at 7:00 on February 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,212 mm (36 mm increase since 16:00 on February 26)	O.P.+ 2,936 mm (18 mm decrease since 16:00 on February 26)	—
	Water level of Turbine Building	O.P.+ 2,723 mm (1 mm decrease since 16:00 on February 26)	O.P.+ 3,195 mm (31 mm increase since 16:00 on February 26)	O.P.+ 2,800 mm (20 mm decrease since 16:00 on February 26)	O.P.+ 2,842 mm (16 mm decrease since 16:00 on February 26)
	Water level of Reactor Building	O.P.+ 4,127 mm (18 mm increase since 16:00 on February 26)	O.P.+ 3,475 mm (33 mm increase since 16:00 on February 26)	O.P.+ 3,009 mm (21 mm decrease since 16:00 on February 26)	O.P.+ 2,859 mm (14 mm decrease since 16:00 on February 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,209 mm (Increase from initial level:5,426 mm, 3 mm increase since 16:00 on February 26) O.P.+ 2,855 mm (Increase from initial level:3,581 mm, 66 mm decrease since 16:00 on February 26) O.P.+ 4,291 mm (Water level from floor:495 mm, No change since 16:00 on February 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:29 on February 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:25 on February 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.