

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 28)**

Water Level of the accumulated water (at 7:00 on February 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,270 mm (35 mm increase since 16:00 on February 27)	O.P.+ 2,944 mm (10 mm increase since 16:00 on February 27)	—
	Water level of Turbine Building	O.P.+ 2,725 mm (1 mm increase since 16:00 on February 27)	O.P.+ 3,244 mm (30 mm increase since 16:00 on February 27)	O.P.+ 2,848 mm (29 mm increase since 16:00 on February 27)	O.P.+ 2,833 mm (1 mm decrease since 16:00 on February 27)
	Water level of Reactor Building	O.P.+ 4,169 mm (28 mm increase since 16:00 on February 27)	O.P.+ 3,523 mm (28 mm increase since 16:00 on February 27)	O.P.+ 3,051 mm (28 mm increase since 16:00 on February 27)	O.P.+ 2,848 mm (2 mm decrease since 16:00 on February 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,213 mm (Increase from initial level:5,430 mm, 3 mm increase since 16:00 on February 27) O.P.+ 2,256 mm (Increase from initial level:2,982 mm, 408 mm decrease since 16:00 on February 27) O.P.+ 4,292 mm (Water level from floor:496 mm, No change since 16:00 on February 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:00 on February 28 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:00 AM on February 28, we stopped the second Cesium Adsorption Apparatus (SARRY) due to the installation of power source.				

For quick publication of the data of water level, values are provided as reference values.