

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 28)**

Water Level of the accumulated water (at 16:00 on February 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,288 mm (18 mm increase since 7:00 on February 28)	O.P.+ 2,945 mm (1 mm increase since 7:00 on February 28)	—
	Water level of Turbine Building	O.P.+ 2,724 mm (1 mm decrease since 7:00 on February 28)	O.P.+ 3,261 mm (17 mm increase since 7:00 on February 28)	O.P.+ 2,843 mm (5 mm decrease since 7:00 on February 28)	O.P.+ 2,838 mm (5 mm increase since 7:00 on February 28)
	Water level of Reactor Building	O.P.+ 4,185 mm (16 mm increase since 7:00 on February 28)	O.P.+ 3,539 mm (16 mm increase since 7:00 on February 28)	O.P.+ 3,055 mm (4 mm increase since 7:00 on February 28)	O.P.+ 2,853 mm (5 mm increase since 7:00 on February 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,213 mm (Increase from initial level:5,430 mm, No change since 7:00 on February 28) O.P.+ 2,343 mm (Increase from initial level:3,069 mm, 87 mm increase since 7:00 on February 28) O.P.+ 4,292 mm (Water level from floor:496 mm, No change since 7:00 on February 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:30 on February 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*On 8:00 at February 28, we stopped operation of the Second Cesium Absorption Apparatus (SARRY) due to the electricity repairs. Since the repairs were completed, we started the apparatus at 16:45 on the same day and at 17:30, it reached constant flow.				

For quick publication of the data of water level, values are provided as reference values.