

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 1)**

Water Level of the accumulated water (at 7:00 on March 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,321 mm (33 mm increase since 16:00 on February 28)	O.P.+ 2,930 mm (15 mm decrease since 16:00 on February 28)	—
	Water level of Turbine Building	O.P.+ 2,724 mm (No change since 16:00 on February 28)	O.P.+ 3,291 mm (30 mm increase since 16:00 on February 28)	O.P.+ 2,811 mm (32 mm decrease since 16:00 on February 28)	O.P.+ 2,831 mm (7 mm decrease since 16:00 on February 28)
	Water level of Reactor Building	O.P.+ 4,212 mm (27 mm increase since 16:00 on February 28)	O.P.+ 3,567 mm (28 mm increase since 16:00 on February 28)	O.P.+ 3,018 mm (37 mm decrease since 16:00 on February 28)	O.P.+ 2,846 mm (7 mm decrease since 16:00 on February 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,216 mm (Increase from initial level:5,433 mm, 3 mm increase since 16:00 on February 28) O.P.+ 2,408 mm (Increase from initial level:3,134 mm, 65 mm increase since 16:00 on February 28) O.P.+ 4,292 mm (Water level from floor:496 mm, No change since 16:00 on February 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:30 on February 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.