

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 1)**

Water Level of the accumulated water (at 16:00 on March 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,343 mm (22 mm increase since 7:00 on March 1)	O.P.+ 2,921 mm (9 mm decrease since 7:00 on March 1)	—
	Water level of Turbine Building	O.P.+ 2,725 mm (1 mm increase since 7:00 on March 1)	O.P.+ 3,308 mm (17 mm increase since 7:00 on March 1)	O.P.+ 2,792 mm (19 mm decrease since 7:00 on March 1)	O.P.+ 2,823 mm (8 mm decrease since 7:00 on March 1)
	Water level of Reactor Building	O.P.+ 4,231 mm (19 mm increase since 7:00 on March 1)	O.P.+ 3,589 mm (22 mm increase since 7:00 on March 1)	O.P.+ 3,018 mm (No change since 7:00 on March 1)	O.P.+ 2,841 mm (5 mm decrease since 7:00 on March 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,218 mm (Increase from initial level:5,435 mm, 2 mm increase since 7:00 on March 1) O.P.+ 2,433 mm (Increase from initial level:3,159 mm, 25 mm increase since 7:00 on March 1) O.P.+ 4,294 mm (Water level from floor:498 mm, 2 mm increase since 7:00 on March 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:30 on February 28   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Due to a camera trouble, the latest data (7:00 May 1) is shown.				

For quick publication of the data of water level, values are provided as reference values.