

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 5)**

Water Level of the accumulated water (at 7:00 on March 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,181 mm (38 mm decrease since 16:00 on March 4)	O.P.+ 2,945 mm (10 mm increase since 16:00 on March 4)	—
	Water level of Turbine Building	O.P.+ 2,726 mm (No change since 16:00 on March 4)	O.P.+ 3,171 mm (32 mm decrease since 16:00 on March 4)	O.P.+ 2,848 mm (11 mm increase since 16:00 on March 4)	O.P.+ 2,830 mm (10 mm increase since 16:00 on March 4)
	Water level of Reactor Building	O.P.+ 4,255 mm (12 mm decrease since 16:00 on March 4)	O.P.+ 3,471 mm (32 mm decrease since 16:00 on March 4)	O.P.+ 3,057 mm (13 mm increase since 16:00 on March 4)	O.P.+ 2,843 mm (9 mm increase since 16:00 on March 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,232 mm (Increase from initial level:5,449 mm, 3 mm increase since 16:00 on March 4) O.P.+ 2,682 mm (Increase from initial level:3,408 mm, 45 mm increase since 16:00 on March 4) O.P.+ 4,294 mm (Water level from floor:498 mm, No change since 16:00 on March 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:12 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:30 on February 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.