

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 5)**

Water Level of the accumulated water (at 16:00 on March 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,159 mm (22 mm decrease since 7:00 on March 5)	O.P.+ 2,950 mm (5 mm increase since 7:00 on March 5)	—
	Water level of Turbine Building	O.P.+ 2,726 mm (No change since 7:00 on March 5)	O.P.+ 3,151 mm (20 mm decrease since 7:00 on March 5)	O.P.+ 2,853 mm (5 mm increase since 7:00 on March 5)	O.P.+ 2,835 mm (5 mm increase since 7:00 on March 5)
	Water level of Reactor Building	O.P.+ 4,244 mm (11 mm decrease since 7:00 on March 5)	O.P.+ 3,453 mm (18 mm decrease since 7:00 on March 5)	O.P.+ 3,062 mm (5 mm increase since 7:00 on March 5)	O.P.+ 2,849 mm (6 mm increase since 7:00 on March 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,233 mm (Increase from initial level:5,450 mm, 1 mm increase since 7:00 on March 5) O.P.+ 2,711 mm (Increase from initial level:3,437 mm, 29 mm increase since 7:00 on March 5) O.P.+ 4,294 mm (Water level from floor:498 mm, No change since 7:00 on March 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:12 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:30 on February 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.