

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 6)**

Water Level of the accumulated water (at 16:00 on March 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,100 mm (21 mm decrease since 7:00 on March 6)	O.P.+ 2,966 mm (7 mm increase since 7:00 on March 6)	—
	Water level of Turbine Building	O.P.+ 2,727 mm (No change since 7:00 on March 6)	O.P.+ 3,101 mm (18 mm decrease since 7:00 on March 6)	O.P.+ 2,870 mm (7 mm increase since 7:00 on March 6)	O.P.+ 2,851 mm (6 mm increase since 7:00 on March 6)
	Water level of Reactor Building	O.P.+ 4,213 mm (11 mm decrease since 7:00 on March 6)	O.P.+ 3,407 mm (15 mm decrease since 7:00 on March 6)	O.P.+ 3,081 mm (8 mm increase since 7:00 on March 6)	O.P.+ 2,861 mm (5 mm increase since 7:00 on March 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,238 mm (Increase from initial level:5,455 mm, 2 mm increase since 7:00 on March 6) O.P.+ 2,795 mm (Increase from initial level:3,521 mm, 36 mm increase since 7:00 on March 6) O.P.+ 4,295 mm (Water level from floor:499 mm, 1 mm increase since 7:00 on March 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:12 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:30 on February 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.