

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 7)**

Water Level of the accumulated water (at 7:00 on March 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,064 mm (36 mm decrease since 16:00 on March 6)	O.P.+ 2,974 mm (8 mm increase since 16:00 on March 6)	—
	Water level of Turbine Building	O.P.+ 2,727 mm (No change since 16:00 on March 6)	O.P.+ 3,071 mm (30 mm decrease since 16:00 on March 6)	O.P.+ 2,880 mm (10 mm increase since 16:00 on March 6)	O.P.+ 2,861 mm (10 mm increase since 16:00 on March 6)
	Water level of Reactor Building	O.P.+ 4,190 mm (23 mm decrease since 16:00 on March 6)	O.P.+ 3,376 mm (31 mm decrease since 16:00 on March 6)	O.P.+ 3,091 mm (10 mm increase since 16:00 on March 6)	O.P.+ 2,870 mm (9 mm increase since 16:00 on March 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,239 mm (Increase from initial level:5,456 mm, 1 mm increase since 16:00 on March 6) O.P.+ 2,847 mm (Increase from initial level:3,573 mm, 52 mm increase since 16:00 on March 6) O.P.+ 4,295 mm (Water level from floor:499 mm, No change since 16:00 on March 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:12 on March 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:30 on February 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.