

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 7)**

Water Level of the accumulated water (at 16:00 on March 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,082 mm (18 mm increase since 7:00 on March 7)	O.P.+ 2,965 mm (9 mm decrease since 7:00 on March 7)	—
	Water level of Turbine Building	O.P.+ 2,727 mm (No change since 7:00 on March 7)	O.P.+ 3,086 mm (15 mm increase since 7:00 on March 7)	O.P.+ 2,860 mm (20 mm decrease since 7:00 on March 7)	O.P.+ 2,863 mm (2 mm increase since 7:00 on March 7)
	Water level of Reactor Building	O.P.+ 4,177 mm (13 mm decrease since 7:00 on March 7)	O.P.+ 3,374 mm (2 mm decrease since 7:00 on March 7)	O.P.+ 3,079 mm (12 mm decrease since 7:00 on March 7)	O.P.+ 2,875 mm (5 mm increase since 7:00 on March 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,241 mm (Increase from initial level:5,458 mm, 2 mm increase since 7:00 on March 7) O.P.+ 2,880 mm (Increase from initial level:3,606 mm, 33 mm increase since 7:00 on March 7) O.P.+ 4,295 mm (Water level from floor:499 mm, No change since 7:00 on March 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 10:12 on March 2 to 9:50 on March 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:30 on February 28   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.