

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 8)**

| | | | | | |
|--|---|--|---|---|---|
| Water Level of the accumulated water (at 7:00 on March 8) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,133 mm (51 mm increase since 16:00 on March 7) | O.P.+ 2,951 mm (14 mm decrease since 16:00 on March 7) | — |
| | Water level of Turbine Building | O.P.+ 2,727 mm (No change since 16:00 on March 7) | O.P.+ 3,130 mm (44 mm increase since 16:00 on March 7) | O.P.+ 2,829 mm (31 mm decrease since 16:00 on March 7) | O.P.+ 2,853 mm (10 mm decrease since 16:00 on March 7) |
| | Water level of Reactor Building | O.P.+ 4,173 mm (4 mm decrease since 16:00 on March 7) | O.P.+ 3,414 mm (40 mm increase since 16:00 on March 7) | O.P.+ 3,044 mm (35 mm decrease since 16:00 on March 7) | O.P.+ 2,866 mm (9 mm decrease since 16:00 on March 7) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,244 mm (Increase from initial level:5,461 mm, 3 mm increase since 16:00 on March 7) O.P.+ 2,939 mm (Increase from initial level:3,665 mm, 59 mm increase since 16:00 on March 7) O.P.+ 4,296 mm (Water level from floor:500 mm, 1 mm increase since 16:00 on March 7) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | — | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28) | — |
| | | Unit 5 and 6 | | | |
| | | | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:25 on March 8 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | * At 8:25 AM on March 8, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. | | | | |

For quick publication of the data of water level, values are provided as reference values.