

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 8)**

Water Level of the accumulated water (at 16:00 on March 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,161 mm (28 mm increase since 7:00 on March 8)	O.P.+ 2,941 mm (10 mm decrease since 7:00 on March 8)	—
	Water level of Turbine Building	O.P.+ 2,730 mm (3 mm increase since 7:00 on March 8)	O.P.+ 3,154 mm (24 mm increase since 7:00 on March 8)	O.P.+ 2,814 mm (15 mm decrease since 7:00 on March 8)	O.P.+ 2,845 mm (8 mm decrease since 7:00 on March 8)
	Water level of Reactor Building	O.P.+ 4,178 mm (5 mm increase since 7:00 on March 8)	O.P.+ 3,439 mm (25 mm increase since 7:00 on March 8)	O.P.+ 3,028 mm (16 mm decrease since 7:00 on March 8)	O.P.+ 2,860 mm (6 mm decrease since 7:00 on March 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,246 mm (Increase from initial level:5,463 mm, 2 mm increase since 7:00 on March 8) O.P.+ 3,187 mm (Increase from initial level:3,913 mm, 248 mm increase since 7:00 on March 8) O.P.+ 4,297 mm (Water level from floor:501 mm, 1 mm increase since 7:00 on March 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:37 on March 8   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:25 AM on March 8, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 2:16 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 3:37 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.