

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 12)**

Water Level of the accumulated water (at 7:00 on March 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,368 mm (30 mm increase since 16:00 on March 11)	O.P.+ 2,842 mm (18 mm decrease since 16:00 on March 11)	—
	Water level of Turbine Building	O.P.+ 2,729 mm (No change since 16:00 on March 11)	O.P.+ 3,335 mm (27 mm increase since 16:00 on March 11)	O.P.+ 2,695 mm (20 mm decrease since 16:00 on March 11)	O.P.+ 2,748 mm (17 mm decrease since 16:00 on March 11)
	Water level of Reactor Building	O.P.+ 4,287 mm (20 mm increase since 16:00 on March 11)	O.P.+ 3,607 mm (27 mm increase since 16:00 on March 11)	O.P.+ 2,903 mm (26 mm decrease since 16:00 on March 11)	O.P.+ 2,772 mm (16 mm decrease since 16:00 on March 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,260 mm (Increase from initial level:5,477 mm, 2 mm increase since 16:00 on March 11) O.P.+ 2,689 mm (Increase from initial level:3,415 mm, 66 mm decrease since 16:00 on March 11) O.P.+ 4,298 mm (Water level from floor:502 mm, No change since 16:00 on March 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:37 on March 8   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.