

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 12)**

Water Level of the accumulated water (at 16:00 on March 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,354 mm (14 mm decrease since 7:00 on March 12)	O.P.+ 2,838 mm (4 mm decrease since 7:00 on March 12)	—
	Water level of Turbine Building	O.P.+ 2,729 mm (No change since 7:00 on March 12)	O.P.+ 3,321 mm (14 mm decrease since 7:00 on March 12)	O.P.+ 2,712 mm (17 mm increase since 7:00 on March 12)	O.P.+ 2,738 mm (10 mm decrease since 7:00 on March 12)
	Water level of Reactor Building	O.P.+ 4,298 mm (11 mm increase since 7:00 on March 12)	O.P.+ 3,613 mm (6 mm increase since 7:00 on March 12)	O.P.+ 2,913 mm (10 mm increase since 7:00 on March 12)	O.P.+ 2,762 mm (10 mm decrease since 7:00 on March 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,262 mm (Increase from initial level:5,479 mm, 2 mm increase since 7:00 on March 12) O.P.+ 2,653 mm (Increase from initial level:3,379 mm, 36 mm decrease since 7:00 on March 12) O.P.+ 4,298 mm (Water level from floor:502 mm, No change since 7:00 on March 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:22 on March 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:37 on March 8   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.