

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 13)**

Water Level of the accumulated water (at 7:00 on March 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,306 mm (48 mm decrease since 16:00 on March 12)	O.P.+ 2,846 mm (8 mm increase since 16:00 on March 12)	—
	Water level of Turbine Building	O.P.+ 2,730 mm (1 mm increase since 16:00 on March 12)	O.P.+ 3,279 mm (42 mm decrease since 16:00 on March 12)	O.P.+ 2,741 mm (29 mm increase since 16:00 on March 12)	O.P.+ 2,736 mm (2 mm decrease since 16:00 on March 12)
	Water level of Reactor Building	O.P.+ 4,307 mm (9 mm increase since 16:00 on March 12)	O.P.+ 3,581 mm (32 mm decrease since 16:00 on March 12)	O.P.+ 2,947 mm (34 mm increase since 16:00 on March 12)	O.P.+ 2,758 mm (4 mm decrease since 16:00 on March 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,265 mm (Increase from initial level:5,482 mm, 3 mm increase since 16:00 on March 12) O.P.+ 2,590 mm (Increase from initial level:3,316 mm, 63 mm decrease since 16:00 on March 12) O.P.+ 4,299 mm (Water level from floor:503 mm, 1 mm increase since 16:00 on March 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:22 on March 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:37 on March 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.