

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 14)**

| | | | | | |
|---|--|--|--|---|---|
| Water Level of the accumulated water (at 7:00 on March 14) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,241 mm (40 mm decrease since 16:00 on March 13) | O.P.+ 2,867 mm (10 mm increase since 16:00 on March 13) | — |
| | Water level of Turbine Building | O.P.+ 2,732 mm (1 mm increase since 16:00 on March 13) | O.P.+ 3,224 mm (34 mm decrease since 16:00 on March 13) | O.P.+ 2,765 mm (13 mm increase since 16:00 on March 13) | O.P.+ 2,750 mm (9 mm increase since 16:00 on March 13) |
| | Water level of Reactor Building | O.P.+ 4,303 mm (6 mm decrease since 16:00 on March 13) | O.P.+ 3,528 mm (37 mm decrease since 16:00 on March 13) | O.P.+ 2,971 mm (12 mm increase since 16:00 on March 13) | O.P.+ 2,769 mm (7 mm increase since 16:00 on March 13) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,268 mm (Increase from initial level:5,485 mm, 1 mm increase since 16:00 on March 13) O.P.+ 2,491 mm (Increase from initial level:3,217 mm, 61 mm decrease since 16:00 on March 13) O.P.+ 4,301 mm (Water level from floor:505 mm, 1 mm increase since 16:00 on March 13) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:22 on March 12) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28) | — |
| | | Unit 5 and 6 | | | |
| | | | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:37 on March 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

For quick publication of the data of water level, values are provided as reference values.