

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 14)**

Water Level of the accumulated water (at 16:00 on March 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,216 mm (25 mm decrease since 7:00 on March 14)	O.P.+ 2,871 mm (4 mm increase since 7:00 on March 14)	—
	Water level of Turbine Building	O.P.+ 2,731 mm (1 mm decrease since 7:00 on March 14)	O.P.+ 3,203 mm (21 mm decrease since 7:00 on March 14)	O.P.+ 2,772 mm (7 mm increase since 7:00 on March 14)	O.P.+ 2,755 mm (5 mm increase since 7:00 on March 14)
	Water level of Reactor Building	O.P.+ 4,295 mm (8 mm decrease since 7:00 on March 14)	O.P.+ 3,503 mm (25 mm decrease since 7:00 on March 14)	O.P.+ 2,977 mm (6 mm increase since 7:00 on March 14)	O.P.+ 2,774 mm (5 mm increase since 7:00 on March 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,270 mm (Increase from initial level:5,487 mm, 2 mm increase since 7:00 on March 14) O.P.+ 2,460 mm (Increase from initial level:3,186 mm, 31 mm decrease since 7:00 on March 14) O.P.+ 4,300 mm (Water level from floor:504 mm, 1 mm decrease since 7:00 on March 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:22 on March 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:37 on March 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.