

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 15)**

Water Level of the accumulated water (at 7:00 on March 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,174 mm (42 mm decrease since 16:00 on March 14)	O.P.+ 2,881 mm (10 mm increase since 16:00 on March 14)	—
	Water level of Turbine Building	O.P.+ 2,731 mm (No change since 16:00 on March 14)	O.P.+ 3,168 mm (35 mm decrease since 16:00 on March 14)	O.P.+ 2,783 mm (11 mm increase since 16:00 on March 14)	O.P.+ 2,765 mm (10 mm increase since 16:00 on March 14)
	Water level of Reactor Building	O.P.+ 4,278 mm (17 mm decrease since 16:00 on March 14)	O.P.+ 3,469 mm (34 mm decrease since 16:00 on March 14)	O.P.+ 2,989 mm (12 mm increase since 16:00 on March 14)	O.P.+ 2,783 mm (9 mm increase since 16:00 on March 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,272 mm (Increase from initial level:5,489 mm, 2 mm increase since 16:00 on March 14) O.P.+ 2,404 mm (Increase from initial level:3,130 mm, 56 mm decrease since 16:00 on March 14) O.P.+ 4,300 mm (Water level from floor:504 mm, No change since 16:00 on March 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:22 on March 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:02 on February 28)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:12 on February 15 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:32 on March 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:32 AM on March 15, we stopped the second Cesium Adsorption Apparatus (SARRY) due to the reliability improvement installation of the second Cesium Adsorption Apparatus (SARRY).				

For quick publication of the data of water level, values are provided as reference values.