

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 18)**

Water Level of the accumulated water (at 7:00 on March 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,125 mm (49 mm increase since 16:00 on March 17)	O.P.+ 2,887 mm (14 mm decrease since 16:00 on March 17)	—
	Water level of Turbine Building	O.P.+ 2,734 mm (No change since 16:00 on March 17)	O.P.+ 3,124 mm (42 mm increase since 16:00 on March 17)	O.P.+ 2,759 mm (33 mm decrease since 16:00 on March 17)	O.P.+ 2,788 mm (10 mm decrease since 16:00 on March 17)
	Water level of Reactor Building	O.P.+ 4,200 mm (6 mm decrease since 16:00 on March 17)	O.P.+ 3,409 mm (39 mm increase since 16:00 on March 17)	O.P.+ 2,975 mm (34 mm decrease since 16:00 on March 17)	O.P.+ 2,804 mm (10 mm decrease since 16:00 on March 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,079 mm (Increase from initial level:5,296 mm, 43 mm decrease since 16:00 on March 17) O.P.+ 2,729 mm (Increase from initial level:3,455 mm, 50 mm increase since 16:00 on March 17) O.P.+ 4,302 mm (Water level from floor:506 mm, 1 mm increase since 16:00 on March 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:27 on March 15)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:02 on March 15 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:32 on March 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.