## Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 18)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on March 18)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,152 mm (27 mm increase since 7:00 on March 18)	O.P.+ 2,877 mm (10 mm decrease since 7:00 on March 18)	_
	Water level of Turbine Building	O.P.+ 2,733 mm (1 mm decrease since 7:00 on March 18)	O.P.+ 3,148 mm (24 mm increase since 7:00 on March 18)	O.P.+ 2,743 mm (16 mm decrease since 7:00 on March 18)	O.P.+ 2,778 mm (10 mm decrease since 7:00 on March 18)
	Water level of Reactor Building	O.P.+ 4,202 mm (2 mm increase since 7:00 on March 18)	O.P.+ 3,434 mm (25 mm increase since 7:00 on March 18)	O.P.+ 2,957 mm (18 mm decrease since 7:00 on March 18)	O.P.+ 2,798 mm (6 mm decrease since 7:00 on March 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building	O.P.+ 4,051 mm (Increase from initial level:5,268 mm, 28 mm decrease since 7:00 on March 18)		
		High Temperature Incinerator Building	O.P.+ 2,769 mm (Increase from initial level:3,495 mm, 40 mm increase since 7:00 on March 18)		
		On-site Bunker Building	O.P.+ 4,303 mm (Water level from floor:507 mm, 1 mm increase since 7:00 on March 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	_	Basement of Unit 3 Turbine Building  →Centralized Radiation Waste  Treatment Facility (Process Main  Building)  Currently being transferred  (Since 10:27 on March 15)	
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:02 on March 15 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:32 on March 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					