

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 19)**

Water Level of the accumulated water (at 7:00 on March 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,193 mm (41 mm increase since 16:00 on March 18)	O.P.+ 2,877 mm (No change since 16:00 on March 18)	—
	Water level of Turbine Building	O.P.+ 2,735 mm (2 mm increase since 16:00 on March 18)	O.P.+ 3,184 mm (36 mm increase since 16:00 on March 18)	O.P.+ 2,743 mm (No change since 16:00 on March 18)	O.P.+ 2,778 mm (No change since 16:00 on March 18)
	Water level of Reactor Building	O.P.+ 4,215 mm (13 mm increase since 16:00 on March 18)	O.P.+ 3,466 mm (32 mm increase since 16:00 on March 18)	O.P.+ 2,957 mm (No change since 16:00 on March 18)	O.P.+ 2,798 mm (No change since 16:00 on March 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,051 mm (Increase from initial level:5,268 mm, No change since 16:00 on March 18) O.P.+ 2,769 mm (Increase from initial level:3,495 mm, No change since 16:00 on March 18) O.P.+ 4,303 mm (Water level from floor:507 mm, No change since 16:00 on March 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:27 on March 15)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:57 on March 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:32 on March 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*1 The most recent data (as of 4:00 PM on March 18) is provided and compared to the data obtained at 7:00 AM on March 18, since data was not acquired due to the power failure occurred at 6:57 AM on March 18. *2 Cesium Adsorption Apparatus has been stopped due to the power failure occurred at 6:57 AM on March 18.				

For quick publication of the data of water level, values are provided as reference values.