

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 19)**

Water Level of the accumulated water (at 16:00 on March 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,216 mm (23 mm increase since 7:00 on March 19)	O.P.+ 2,858 mm (19 mm decrease since 7:00 on March 19)	—
	Water level of Turbine Building	O.P.+ 2,735 mm (No change since 7:00 on March 19)	O.P.+ 3,204 mm (20 mm increase since 7:00 on March 19)	O.P.+ 2,733 mm (10 mm decrease since 7:00 on March 19)	O.P.+ 2,752 mm (26 mm decrease since 7:00 on March 19)
	Water level of Reactor Building	O.P.+ 4,226 mm (11 mm increase since 7:00 on March 19)	O.P.+ 3,481 mm (15 mm increase since 7:00 on March 19)	O.P.+ 2,935 mm (22 mm decrease since 7:00 on March 19)	O.P.+ 2,798 mm (No change since 7:00 on March 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,210 mm (Increase from initial level:5,427 mm, 159 mm increase since 7:00 on March 19) O.P.+ 2,857 mm (Increase from initial level:3,583 mm, 88 mm increase since 7:00 on March 19) O.P.+ 4,305 mm (Water level from floor:509 mm, 2 mm increase since 7:00 on March 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 10:27 on March 15 to 10:34 on March 19)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:17 on March 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:32 on March 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*1 Compared with the data of 16:00 March 18 since the data of 19:00 March 19 could not have recorded due to the power supply facilities failure occurred at 18:57 March 18. *2 Written the latest data of 16:00 March 18 and compared with the data of 7:00 March 18 since the data could not have recorded due to the power supply facilities failure occurred at 18:57 March 18. *3 We stopped transferring water from Unit 3 Turbine Building basement to the Centralized Radiation Waste Treatment Facility (Process Main Building) for we couldn't monitor the water level of the accumulated water at the Centralized Radiation Waste Treatment Facility (Process Main Building) due to the power supply facility failure which occurred at around 18:57 on March 18. *4 The cesium absorption apparatus (Kurion) stopped due to the power supply facility failure which occurred at around 18:57 on March 18. It was restarted at 12:01 PM today after the power supply facility had been checked and the supply started. The steady flow rate was achieved at 12:17 PM.				

For quick publication of the data of water level, values are provided as reference values.