

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 21)**

Water Level of the accumulated water (at 7:00 on March 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,306 mm (36 mm increase since 16:00 on March 20)	O.P.+ 2,843 mm (15 mm decrease since 16:00 on March 20)	—
	Water level of Turbine Building	O.P.+ 2,737 mm (3 mm increase since 16:00 on March 20)	O.P.+ 3,281 mm (31 mm increase since 16:00 on March 20)	O.P.+ 2,708 mm (33 mm decrease since 16:00 on March 20)	O.P.+ 2,741 mm (11 mm decrease since 16:00 on March 20)
	Water level of Reactor Building	O.P.+ 4,275 mm (25 mm increase since 16:00 on March 20)	O.P.+ 3,560 mm (24 mm increase since 16:00 on March 20)	O.P.+ 2,920 mm (33 mm decrease since 16:00 on March 20)	O.P.+ 2,798 mm (6 mm decrease since 16:00 on March 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,839 mm (Increase from initial level:5,056 mm, 38 mm decrease since 16:00 on March 20) O.P.+ 3,022 mm (Increase from initial level:3,748 mm, 67 mm increase since 16:00 on March 20) O.P.+ 4,305 mm (Water level from floor:509 mm, No change since 16:00 on March 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:56 on March 20)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:17 on March 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:32 on March 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*1 The most recent data (as of 4:00 PM on March 18) is provided and compared to data obtained at 7:00 AM on March 18, since data was not acquired due to the power failure occurred at 6:57 AM on March 18.				

For quick publication of the data of water level, values are provided as reference values.