

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 21)**

Water Level of the accumulated water (at 16:00 on March 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,325 mm (19 mm increase since 7:00 on March 21)	O.P.+ 2,834 mm (9 mm decrease since 7:00 on March 21)	—
	Water level of Turbine Building	O.P.+ 2,736 mm (1 mm decrease since 7:00 on March 21)	O.P.+ 3,298 mm (17 mm increase since 7:00 on March 21)	O.P.+ 2,693 mm (15 mm decrease since 7:00 on March 21)	O.P.+ 2,733 mm (8 mm decrease since 7:00 on March 21)
	Water level of Reactor Building	O.P.+ 4,290 mm (15 mm increase since 7:00 on March 21)	O.P.+ 3,574 mm (14 mm increase since 7:00 on March 21)	O.P.+ 2,903 mm (17 mm decrease since 7:00 on March 21)	O.P.+ 2,754 mm (44 mm decrease since 7:00 on March 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,929 mm (Increase from initial level:5,146 mm, 90 mm increase since 7:00 on March 21) O.P.+ 3,082 mm (Increase from initial level:3,808 mm, 60 mm increase since 7:00 on March 21) O.P.+ 4,304 mm (Water level from floor:508 mm, 1 mm decrease since 7:00 on March 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:56 on March 20)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:32 on March 15   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*1 The data which was not obtained due to the power facility failure which occurred at about 18:57 on March 18 has recovered today and was obtained. The data before the failure (16:00 on March 18) and the latest data (16:00 on March 21) is compared.				

For quick publication of the data of water level, values are provided as reference values.