

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 22)**

Water Level of the accumulated water (at 16:00 on March 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,369 mm (12 mm increase since 7:00 on March 22)	O.P.+ 2,810 mm (5 mm decrease since 7:00 on March 22)	—
	Water level of Turbine Building	O.P.+ 2,736 mm (No change since 7:00 on March 22)	O.P.+ 3,336 mm (11 mm increase since 7:00 on March 22)	O.P.+ 2,680 mm (13 mm increase since 7:00 on March 22)	O.P.+ 2,707 mm (10 mm decrease since 7:00 on March 22)
	Water level of Reactor Building	O.P.+ 4,310 mm (16 mm increase since 7:00 on March 22)	O.P.+ 3,621 mm (20 mm increase since 7:00 on March 22)	O.P.+ 2,882 mm (5 mm increase since 7:00 on March 22)	O.P.+ 2,734 mm (7 mm decrease since 7:00 on March 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,202 mm (Increase from initial level:5,419 mm, 52 mm increase since 7:00 on March 22) O.P.+ 3,115 mm (Increase from initial level:3,841 mm, 42 mm decrease since 7:00 on March 22) O.P.+ 4,305 mm (Water level from floor:509 mm, 1 mm increase since 7:00 on March 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 14:48 on March 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on March 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*1 From 9:56 AM March 20 to 10:12 AM March 22, the accumulated water in Turbine Building Unit 3 was transferred to Centralized Radiation Waste Treatment Facility. *2 After the reliability improvement work had been done with the Second Cesium Absorption Apparatus (SARRY), we started it at 12:06 on March 22 and confirmed normal flow at 13:00.				

For quick publication of the data of water level, values are provided as reference values.