

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 25)**

Water Level of the accumulated water (at 7:00 on March 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,181 mm (40 mm decrease since 16:00 on March 24)	O.P.+ 2,853 mm (11 mm increase since 16:00 on March 24)	—
	Water level of Turbine Building	O.P.+ 2,739 mm (1 mm increase since 16:00 on March 24)	O.P.+ 3,173 mm (36 mm decrease since 16:00 on March 24)	O.P.+ 2,749 mm (11 mm increase since 16:00 on March 24)	O.P.+ 2,733 mm (10 mm increase since 16:00 on March 24)
	Water level of Reactor Building	O.P.+ 4,290 mm (12 mm decrease since 16:00 on March 24)	O.P.+ 3,483 mm (33 mm decrease since 16:00 on March 24)	O.P.+ 2,956 mm (11 mm increase since 16:00 on March 24)	O.P.+ 2,751 mm (9 mm increase since 16:00 on March 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,207 mm (Increase from initial level:5,424 mm, 2 mm increase since 16:00 on March 24) O.P.+ 2,928 mm (Increase from initial level:3,654 mm, 39 mm decrease since 16:00 on March 24) O.P.+ 4,306 mm (Water level from floor:510 mm, 1 mm decrease since 16:00 on March 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 14:48 on March 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on March 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.