

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 25)**

Water Level of the accumulated water (at 16:00 on March 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,196 mm (15 mm increase since 7:00 on March 25)	O.P.+ 2,843 mm (10 mm decrease since 7:00 on March 25)	—
	Water level of Turbine Building	O.P.+ 2,739 mm (No change since 7:00 on March 25)	O.P.+ 3,187 mm (14 mm increase since 7:00 on March 25)	O.P.+ 2,729 mm (20 mm decrease since 7:00 on March 25)	O.P.+ 2,736 mm (3 mm increase since 7:00 on March 25)
	Water level of Reactor Building	O.P.+ 4,285 mm (5 mm decrease since 7:00 on March 25)	O.P.+ 3,477 mm (6 mm decrease since 7:00 on March 25)	O.P.+ 2,942 mm (14 mm decrease since 7:00 on March 25)	O.P.+ 2,755 mm (4 mm increase since 7:00 on March 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,208 mm (Increase from initial level:5,425 mm, 1 mm increase since 7:00 on March 25) O.P.+ 2,905 mm (Increase from initial level:3,631 mm, 23 mm decrease since 7:00 on March 25) O.P.+ 4,307 mm (Water level from floor:511 mm, 1 mm increase since 7:00 on March 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 14:48 on March 22 to 9:55 on March 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on March 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.