

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 26)**

Water Level of the accumulated water (at 7:00 on March 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,240 mm (44 mm increase since 16:00 on March 25)	O.P.+ 2,829 mm (14 mm decrease since 16:00 on March 25)	—
	Water level of Turbine Building	O.P.+ 2,739 mm (No change since 16:00 on March 25)	O.P.+ 3,226 mm (39 mm increase since 16:00 on March 25)	O.P.+ 2,697 mm (32 mm decrease since 16:00 on March 25)	O.P.+ 2,726 mm (10 mm decrease since 16:00 on March 25)
	Water level of Reactor Building	O.P.+ 4,283 mm (2 mm decrease since 16:00 on March 25)	O.P.+ 3,506 mm (29 mm increase since 16:00 on March 25)	O.P.+ 2,907 mm (35 mm decrease since 16:00 on March 25)	O.P.+ 2,747 mm (8 mm decrease since 16:00 on March 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,210 mm (Increase from initial level:5,427 mm, 2 mm increase since 16:00 on March 25) O.P.+ 2,868 mm (Increase from initial level:3,594 mm, 37 mm decrease since 16:00 on March 25) O.P.+ 4,307 mm (Water level from floor:511 mm, No change since 16:00 on March 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on March 22   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.