

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 26)**

Water Level of the accumulated water (at 16:00 on March 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,265 mm (25 mm increase since 7:00 on March 26)	O.P.+ 2,820 mm (9 mm decrease since 7:00 on March 26)	—
	Water level of Turbine Building	O.P.+ 2,741 mm (2 mm increase since 7:00 on March 26)	O.P.+ 3,246 mm (20 mm increase since 7:00 on March 26)	O.P.+ 2,681 mm (16 mm decrease since 7:00 on March 26)	O.P.+ 2,718 mm (8 mm decrease since 7:00 on March 26)
	Water level of Reactor Building	O.P.+ 4,284 mm (1 mm increase since 7:00 on March 26)	O.P.+ 3,524 mm (18 mm increase since 7:00 on March 26)	O.P.+ 2,891 mm (16 mm decrease since 7:00 on March 26)	O.P.+ 2,740 mm (7 mm decrease since 7:00 on March 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,211 mm (Increase from initial level:5,428 mm, 1 mm increase since 7:00 on March 26) O.P.+ 2,848 mm (Increase from initial level:3,574 mm, 20 mm decrease since 7:00 on March 26) O.P.+ 4,307 mm (Water level from floor:511 mm, No change since 7:00 on March 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on March 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.