

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 27)**

Water Level of the accumulated water (at 7:00 on March 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,300 mm (35 mm increase since 16:00 on March 26)	O.P.+ 2,803 mm (17 mm decrease since 16:00 on March 26)	—
	Water level of Turbine Building	O.P.+ 2,741 mm (No change since 16:00 on March 26)	O.P.+ 3,276 mm (30 mm increase since 16:00 on March 26)	O.P.+ 2,657 mm (24 mm decrease since 16:00 on March 26)	O.P.+ 2,703 mm (15 mm decrease since 16:00 on March 26)
	Water level of Reactor Building	O.P.+ 4,290 mm (6 mm increase since 16:00 on March 26)	O.P.+ 3,556 mm (32 mm increase since 16:00 on March 26)	O.P.+ 2,864 mm (27 mm decrease since 16:00 on March 26)	O.P.+ 2,726 mm (14 mm decrease since 16:00 on March 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,213 mm (Increase from initial level:5,430 mm, 2 mm increase since 16:00 on March 26) O.P.+ 2,816 mm (Increase from initial level:3,542 mm, 32 mm decrease since 16:00 on March 26) O.P.+ 4,308 mm (Water level from floor:512 mm, 1 mm increase since 16:00 on March 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:54 on March 27 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:54 AM on March 27, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.