Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 27)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on March 27)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,320 mm (20 mm increase since 7:00 on March 27)	O.P.+ 2,790 mm (13 mm decrease since 7:00 on March 27)	_
	Water level of Turbine Building	O.P.+ 2,739 mm (2 mm decrease since 7:00 on March 27)	O.P.+ 3,294 mm (18 mm increase since 7:00 on March 27)	O.P.+ 2,644 mm (13 mm decrease since 7:00 on March 27)	O.P.+ 2,693 mm (10 mm decrease since 7:00 on March 27)
	Water level of Reactor Building	O.P.+ 4,295 mm (5 mm increase since 7:00 on March 27)	O.P.+ 3,575 mm (19 mm increase since 7:00 on March 27)	O.P.+ 2,852 mm (12 mm decrease since 7:00 on March 27)	O.P.+ 2,719 mm (7 mm decrease since 7:00 on March 27)
	Water level	Process Main Building	O.P.+ 4,214 mm (Increase from initial level:5,431 mm, 1 mm increase since 7:00 on March 27)		
	of each building in the Centralized Radiation Waste	High Temperature Incinerator Building	O.P.+ 3,062 mm (Increase from initial level:3,788 mm, 246 mm increase since 7:00 on March 27)		
	Treatment Facility	On-site Bunker Building	O.P.+ 4,309 mm (Water level from floor:513 mm, 1 mm increase since 7:00 on March 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	_	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	_
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:00 on March 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
		7, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 2:23 PM on the same day, the apparatus was restarted , and the steady flow rate was achieved at 3:00 PM on the same day.			

For quick publication of the data of water level, values are provided as reference values.